

ADDENDUM NO. 3

DATE: January 16, 2012

PROJECT: Indiana Convention Center Toilet Room and Ceiling Upgrades

PROJECT NUMBER: 11120.00

OWNER: The Capital Improvement Board of Managers of Marion County,
Indiana
c/o Indiana Convention Center
100 South Capitol Avenue
Indianapolis, Indiana 46225

ARCHITECT:

RATIO ARCHITECTS, INC.
Suite 100, Schrader Building
107 South Pennsylvania Street
Indianapolis, Indiana 46204-3684
Phone: (317) 633-4040

MECHANICAL / ELECTRICAL ENGINEER:

CIRCLE DESIGN GROUP
5510 S. East Street, Suite F
Indianapolis, IN 46227
317-781-6200

This Addendum is issued in accordance with the provisions of The General Conditions of the Contract for Construction, Article 1 Contract Documents, and becomes a part of the Contract Documents as provided therein.

The information contained herein modifies the original Bidding Documents dated December 16, 2012 and all prior Addenda as applicable. Requirements of the original Bidding Documents and previous Addenda remain in effect except as modified by this Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

PART 1 – PROJECT MANUAL CHANGES

SECTION 003000 - AVAILABLE INFORMATION

Add the following comment to paragraph 1.3 to read as follows :

Attached herewith is a wall section from the existing as built drawings. This is being issued to clarify the extent of the existing concrete block wall that is to be removed after removal of the existing lay in ceiling and plaster bulkhead and prior to new construction in the west wall of the women's restroom. The block wall is to be removed from the floor to the existing structural beam and slab. Verify the location of the existing beam prior to removal of the wall. New metal stud and backer board wall is to be constructed with the new face of ceramic tile in the same plane as the existing face of ceramic tile.

PART 2 – DRAWING CHANGES NOT USED

PART 3 –PREVIOUS ADDENDA CHANGES

ADDENDUM NO. 1:

1. No Change

ADDENDUM NO. 2:

1. No Change

PART 4 – ATTACHMENTS

1. Existing Drawing issued for clarification.

END OF ADDENDUM NO. 3